

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD			4				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD			4				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	11/13/2011	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2012	
CROSS CONNECTION EXEMPTION	3/1/2020	

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Organic Chemicals M&R Violation	10/1/08 - 12/31/08	3	2/27/2010		3/9/2010	
Repeat Total Coliform M&R Violation	10/1/11 - 10/31/11	2	4/20/2012		4/30/2012	
Total Coliform M&R Violation	11/1/11 - 11/30/11	2	4/20/2012		4/30/2012	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	3	ENTRY POINT	A				
		4	DISTRIBUTION SYSTEM	A	Y		Y	Y
		B 1	BOYS ROOM	A		2		
		CRF	CLASS ROOM FAUCET	A		2		
		DF 1	DRINKING FOUNTAIN	A		2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		G 1	GIRLS ROOM	A		2		
		LAB 1	LAB FAUCET 1	A	Y	2		Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10012	WELL	2	WELL	A				

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0040442	TALCOTT MOUNTAIN SCIENCE CENTER #1			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
350 MONTEVIDEO RD				4				

Towns Served:

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: **SMALL WATER SYSTEM**

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020

Contact Information

Name		Organization		Job Title		
Mr. Jonathan Craig		Talcott Mountain Science Ctr		Director		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Montevideo Road				Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-677-8571						

Contact Role(s): **Legal Contact**

Name		Organization		Job Title		
Talcott Mtn Science Ctr						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
350 Montevideo Rd				Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	

Contact Role(s): **Owner**

Name		Organization		Job Title		
Mr. John Pellino		Talcott Mountain Science Cntr		Associate Director		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
324 Montevideo Road				Avon	CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-677-8571	214	860-676-0421			jpellino@tmsc.org	

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD				1				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (0999)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BOYS ROOM (BRF2)	1/1/18 - 12/31/18	8/1-8/31	Complete
	1/1/19 - 12/31/19	8/1-8/31	
	1/1/20 - 12/31/20	8/1-8/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/20	6/1-9/30	
	1/1/21 - 12/31/23	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)		1 routine (RT) per quarter	
Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD			1				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		Complete
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		Complete
	1/1/20 - 12/31/22		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Water System Facility: WELL (WSF ID: 10014)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		Complete
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 1/1/2005	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	11/1/2018 - 11/30/2018			N
	12/1/2018 - 12/31/2018			N
	1/1/2019 - 1/31/2019			N
	2/1/2019 - 2/28/2019			N
	3/1/2019 - 3/31/2019			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD			1				

Towns Served:

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2005	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
4/1/2019 - 4/30/2019			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2020	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Chlorine M&R Violation	8/1/12 - 8/31/12	3	10/15/2013		10/25/2013	
Chlorine M&R Violation	7/1/12 - 7/31/12	3	10/15/2013		10/25/2013	
Chlorine M&R Violation	9/1/12 - 9/30/12	3	11/9/2013		11/19/2013	
Chlorine M&R Violation	7/1/18 - 9/30/18	3	11/20/2019		11/30/2019	
Chlorine M&R Violation	10/1/18 - 12/31/18	3	2/13/2020		2/23/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	3	ENTRY POINT	A				
		4	DISTRIBUTION SYSTEM	A	Y		Y	Y
		BRF2	BOYS ROOM	A	Y	2		Y
		BRFA2	BREAK ROOM	A		2		
		DF2	DRINKING FOUNTAIN	A		2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GRF2	GIRLS ROOM	A		2		
		KF	KITCHEN FAUCET	A		2		
		OF	OUTSIDE FAUCET	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10014	WELL	2	WELL	A				
1065	WATER TREATMENT PLANT							

Certified Operator Information

Water System Facility: WATER TREATMENT PLANT (WSF ID: 1065)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHOQUINARD, THOMAS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2020

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0040483	TALCOTT MOUNTAIN SCIENCE CENTER #2			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
MONTEVIDEO ROAD				1				

Towns Served:

Contact Information

Name				Organization			Job Title		
Mr. Jonathan Craig				Talcott Mountain Science Ctr			Director		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Montevideo Road						Avon		CT	06001
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-677-8571									

Contact Role(s): **Legal Contact**

Name				Organization			Job Title		
Mr. John Pellino				Talcott Mountain Science Cntr			Associate Director		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
324 Montevideo Road						Avon		CT	06001
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-677-8571		214	860-676-0421				jpellino@tmsc.org		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0040493	THE ARC OF THE FARMINGTON VALLEY			NTNC	50	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
255 OLD MOUNTAIN ROAD			3				

Towns Served:

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/11 - 12/31/19		
	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
DISTRIBUTION SYSTEM (4)	1/1/16 - 12/31/18	6/1-9/30	Complete
	1/1/19 - 12/31/21	6/1-9/30	
	1/1/22 - 12/31/24	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/18 - 12/31/18		Complete
	1/1/19 - 3/31/19		
	4/1/19 - 6/30/19		
	7/1/19 - 9/30/19		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/18 - 12/31/18		Complete
	1/1/19 - 12/31/19		
	1/1/20 - 12/31/20		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/19		
	1/1/20 - 12/31/22		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0040493	THE ARC OF THE FARMINGTON VALLEY			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
255 OLD MOUNTAIN ROAD				3				

Towns Served:

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/18 - 12/31/20		
	1/1/21 - 12/31/23		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2018	
CROSS CONNECTION SURVEY REPORT	3/1/2019	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10015	WELL	2	WELL	A				
934	FARMINGTON VALLEY ARC PLANT							

Certified Operator Information

Water System Facility: FARMINGTON VALLEY ARC PLANT (WSF ID: 934)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WEID, JEREMIAH J.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2021
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2019

Contact Information

Name				Organization			Job Title		
Ms. Patricia Nadeau				Arc of The Farmington Valley			Dir. of Res Services		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
225 Commerce Dr						Canton		CT	06019
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-693-6662		106	860-693-8662			860-641-4560	pnadeau@favarh.org		
Contact Role(s): Administrative Contact, Legal Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0040493	THE ARC OF THE FARMINGTON VALLEY	NTNC	50	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
255 OLD MOUNTAIN ROAD		3			
Towns Served:					
Name		Organization		Job Title	
Mr. Stephen E. Morris		Arc of Farmington Valley		Exe Director	
Mailing Address Line One		Mailing Address Line Two		City	State
PO Box 1099				Canton	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-693-6662	123				smorris@favarh.org
Contact Role(s): Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.